

# Register of Approved Products for use in Water Services Infrastructure

August 2024

Revision 2.3



This document was developed for the benefit of the city and district councils of Hutt, Porirua, Upper Hutt, South Wairarapa and Wellington and Greater Wellington Regional Council.

### Revision history

Rev No	Revision Description	Date
Rev 1.0		Aug 2019
Rev 2.0	Updated formatting and inclusions	Nov 2021
Rev 2.1	Updated product detail	Dec 2021
Rev 2.2	Added summary of changes table, amendments to product requirements	Mar 2022
Rev 2.3	Updated with additional approved products Illustrations included as general guide to product type Removed APR application numbers	August 2024

## Contents

<b>1. Introduction .....</b>	<b>4</b>
1.1. Summary of changes	4
<b>2. Pipes.....</b>	<b>6</b>
2.1. Concrete lined ductile iron pipe	6
2.2. Polyvinylchloride pipe	7
2.3. Polyethylene (PE) pipe AS/NZS 4130	8
2.4. Steel pipe (Water Supply Only)	8
2.5. Acrylonitrile butadiene styrene (ABS) Pipe	8
2.6. Concrete pipe AS/NZS 4058	8
2.7. Vitrified clay	10
2.8. Profiled polyethylene and polypropylene pipes	11
<b>3. Fittings, Couplings &amp; Connectors.....</b>	<b>12</b>
3.1. Ductile iron fittings	12
3.2. Polyethylene electrofusion fittings	12
3.3. Polyethylene compression fittings – Repair Only	13
3.4. Full faced reducing stub flanges (AS/NZS 4087)	13
3.5. Mechanical couplings	14
3.6. Mechanical couplings for polyethylene pipes	15
3.7. Dismantling joints	15
3.8. Flanged flexible joints	16
3.9. Tapping bands for water connections	16
3.10. Repair clamps	16
3.11. Other	17
<b>4. Valves.....</b>	<b>18</b>
4.2. Check valves	19
4.3. Globe control valves – Pressure reducing, sustaining and relief valves	19
4.4. Service valves (Tobies)	19
4.5. Backflow prevention Devices	20
4.6. Hydrants	20
4.7. Other valves	20
<b>5. Water Meters .....</b>	<b>21</b>
<b>6. Manholes and Streetware.....</b>	<b>22</b>
6.1. Manhole covers	22
6.2. Manhole safety grilles	23
6.3. Prefabricated manholes systems	23
6.4. Surface boxes	24

## 1. Introduction

This document lists products that are approved for use in conjunction with [STD\\_0001](#) *Regional Standard for Water Services* and [STD\\_0002](#) *Regional Specification for Water Services*. The list is generally restricted to commonly used fixtures and fittings used on the stormwater (SW), wastewater (WW) or water supply (WS) networks. Specialised items, such as pumps, radio transmitters and electrical components., are not included. Prior to design, the designer should confirm the specifications for these specialised items with Wellington Water.

Where a product is not listed, it should be assumed that the product has not been approved and confirmation or project-specific dispensation be sought from Wellington Water.

Illustrations are provided only as an aid to general identification of product type.

Wellington Water retains the right to review and withdraw product approval from this register at any time.

### 1.1. Summary of changes

Version	Section	Description of revision
2.1	<b>Error! Reference source not found. Error! Reference source not found.</b>	Kurimoto SRDIP pipe: <ul style="list-style-type: none"> <li>Specified compliance with ISO 16134)</li> <li>Specified seismically resilient joint system</li> </ul>
	<b>Error! Reference source not found. Error! Reference source not found.</b>	Corrected product name from Sintalock to Sintakote
2.2	1.1 Summary of changes	Added section
	<b>Error! Reference source not found. Error! Reference source not found.</b>	Restored general requirements for rubber ring joints and SN16 minimum (erroneously removed from v2.0)
2.3	Throughout	Removed extraneous columns from tables, clarified relevant networks for each product
	<b>Error! Reference source not found. Steel pipe</b>	Clarified that Sintakote pipe is approved with Sintalock joints only
	2.6 Concrete pipe	Added PinnacleX
	3.2. Polyethylene electrofusion fittings	Restored Agru approval
	3.4 Full faced reducing flanges	Added a new section including Simona, Solo and Plasson Reducing Full Faced Flanges
	3.5. Mechanical couplings	Added HIWA bolted unrestrained mechanical coupler and flange adapter products.
	3.7. Dismantling joints	Added HIWA dismantling joint product
	3.9 Tapping bands	Added Promains Hermetica SS Permanent Repair Clamp 380 mm clamp
	3.10 Repair clamps	Added Promains Hermetica SS Permanent Repair Clamp 210 mm clamp and 380 mm clamp
	3.11 - Other	Renamed section to "Other"
	4.1. Gate valves – Resilient Seated	Added HIWA valve product and Hawle E3 Resilient Seated Gate Valves
	4.4 Service valves (tobies)	Added Acuflo Composite Manifolds – Only for instances where metallic manifolds are not available
	5 Water meters	Added Sensus 640 and Sensus iPERL inline meter
	6.1 Manhole covers	Added Pamrex 600 D400 Manhole Frame and Cover

Version	Section	Description of revision
	6.3 Prefabricated manhole systems	Added Hutt Concrete Products Twin Lake <sup>®</sup> Concrete Manhole System. Approved on Trial basis only.

## 2. Pipes

All pipes shall be rated to the appropriate pressure class as defined in the Regional Standard for Water Services.

Where scenarios exist where the products listed below are not suitable, the Regional Standard for Water Services and Regional Specification for Water Services should be consulted for alternatives.

### 2.1. Concrete lined ductile iron pipe

Product	Notes	WS	WW	SW
Tyton Xcel Z+	<ul style="list-style-type: none"> <li>Must be used with Tyton-lok rings.</li> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> <li>Used for repairs on existing pipes only</li> </ul>	✓		
Tyton Xtreme Z+	<ul style="list-style-type: none"> <li>Must be used with Tyton-lok rings.</li> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> </ul>		✓	
Saint Gobain PAM pipe (AS/NZS 2280)	<ul style="list-style-type: none"> <li>Must be used with Grip-Lok rings.</li> <li>Zinalium coating required as a minimum</li> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> <li>Used for repairs on existing pipes only</li> </ul>	✓		
Humes AS/NZS 2280 DICL pipe (Ø150 & Ø200 PN35 only)	<ul style="list-style-type: none"> <li>Must be used be used with Grip-lok restraining rings.</li> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> <li>Used for repairs on existing pipes only</li> </ul>	✓		
Gillies Hydrotite AS/NZS 2280 DICL pipe	<ul style="list-style-type: none"> <li>Must be used be used with Grip-lok restraining rings.</li> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> <li>Used for repairs on existing pipes only</li> </ul>	✓		

Saint Gobain Concrete Lined Ductile Iron Pipe (ISO 2531)	<ul style="list-style-type: none"> <li>Proprietary rubber ring joints with restrained jointing rated to a minimum PN16. Concrete or epoxy lining plus epoxy over zinc coating.</li> </ul>	✓		
Kurimoto SRDIP pipe (complies with ISO 16134)	<ul style="list-style-type: none"> <li>Polyethylene wrap to be used where ground conditions or specifications require. Alternative coating may be considered by Council upon application</li> <li>To be used only on trunk mains and/or mains without service connections</li> <li>DN 100, 150, 200, 300 and 400 only</li> <li>Seismically resilient joint system</li> </ul>	✓		

## 2.2. Polyvinylchloride pipe

Product	Notes	WS	WW	SW
MPVC, RRJ Series 1 (AS/NZS 4765)	<ul style="list-style-type: none"> <li>Pressure classification as per Regional Specification for Water Services</li> <li>EPDM rings</li> <li>Series 2 can be used for repairs on existing Series 2 pipelines</li> </ul>	✓		
UPVC, RRJ Series 1 (AS/NZS 1477)	<ul style="list-style-type: none"> <li>Pressure classification as per Regional Specification for Water Services</li> <li>EPDM rings</li> <li>Series 2 can be used for repairs on existing Series 2 pipelines</li> </ul>	✓		
PVC-U AS/NZS 1260	<ul style="list-style-type: none"> <li>Permitted for public mains in Hutt City, Upper Hutt City and Porirua City</li> <li>Permitted for laterals connecting to private drainage</li> <li>Can be used for repairing existing PVC or Vitrified Clay drains</li> <li>Rubber ring joints only, minimum SN16</li> </ul>		✓	✓

### 2.3. Polyethylene (PE) pipe AS/NZS 4130

Product	Notes	WS	WW	SW
Polyethylene PE100 (Series 1) Pressure Pipe	<ul style="list-style-type: none"> <li>To be used for general reticulation pipes in the public network, and wastewater and stormwater rising pressure mains.</li> <li>Joints in accordance with the Regional Specification for Water Services</li> <li>SDR 11</li> <li>PN 16 minimum</li> </ul>	✓	✓	✓
Polyethylene PE100 (Series 1) Drainage pipes	<ul style="list-style-type: none"> <li>Joints in accordance with the Regional Specification for Water Services</li> <li>SDR 17.6 maximum</li> </ul>		✓	✓

### 2.4. Steel pipe (Water Supply Only)

Product	Notes
Concrete lined mild steel (NZS 4442)	<ul style="list-style-type: none"> <li>Externally coated with an approved tape wrapping system</li> <li>Choose min. wall thicknesses in-line with NZS 4442 Table 2 Column B or as specified in the specification</li> </ul>
Sintakote concrete lined steel with Sintalock joints (AS 1579)	<ul style="list-style-type: none"> <li>For pipe 600mm nominal bore or smaller</li> <li>Only lap welded or flanged jointing type system approved</li> </ul>
Stainless Steel (ASTM A312)	<ul style="list-style-type: none"> <li>Schedule 40</li> <li>316 or 316L for underground/wet-well applications</li> <li>304 or 304L for drywell/chamber or above ground applications</li> </ul>

### 2.5. Acrylonitrile butadiene styrene (ABS) Pipe

Product	Notes	WS	WW	SW
ABS (AS/NZS 3518) Series 1 (Metric)	For pump station pipe work. Generally not used in underground applications.	✓	✓	

### 2.6. Concrete pipe AS/NZS 4058

Product	Notes	WS	WW	SW
---------	-------	----	----	----



Product	Notes	WS	WW	SW
Humes Spun pipe	<ul style="list-style-type: none"> <li>• Rubber-ring jointed and Class 2 minimum</li> <li>• Will not typically be permitted for drains 375 mm and smaller for use in the wastewater network</li> <li>• When used for wastewater, pipes must be factory lined with PE or manufactured with approved additives and a sacrificial layer to achieve durability requirements.</li> <li>• Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval</li> <li>• Shall only be installed on gravity pipelines.</li> </ul>		✓	✓
RCP/VCT Pipe	<ul style="list-style-type: none"> <li>• Rubber-ring jointed and Class 2 minimum</li> <li>• Will not typically be permitted for drains 375 mm and smaller for use in the wastewater network</li> <li>• When used for wastewater, pipes must be factory lined with PE or manufactured with approved additives and a sacrificial layer to achieve durability requirements.</li> <li>• Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval</li> <li>• Shall only be installed on gravity pipelines.</li> </ul>		✓	✓
Hynds Hyspec Spun pipe	<ul style="list-style-type: none"> <li>• Rubber-ring jointed and Class 2 minimum</li> <li>• Will not typically be permitted for drains 375 mm and smaller for use in the wastewater network</li> <li>• When used for wastewater, pipes must be factory lined with PE or manufactured with approved additives and a sacrificial layer to achieve durability requirements.</li> <li>• Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval</li> <li>• Shall only be installed on gravity pipelines.</li> </ul>		✓	✓

Product	Notes	WS	WW	SW
Hynds Pinnacle pipe and pre-lubricated sliding rubber rings	<ul style="list-style-type: none"> <li>EDPM 40 rubber-ring jointed</li> <li>Approval is valid for the following products:                             <ul style="list-style-type: none"> <li>Belled socket joint, Class 2: DN 675 – 1350, DN 1650</li> <li>Belled socket joint, Class 4: DN 675 – 825, DN 1050 – 1350, DN 1650</li> <li>In-wall joint, Class 2 and 4: DN 1950, 2100, 2550</li> <li>Forsheda 146 pre-lubricated sliding rubber rings (EDPM 40 only)</li> </ul> </li> <li>When used for wastewater, pipes must be factory lined with PE or manufactured with approved additives and a sacrificial layer to achieve durability requirements.</li> <li>Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval.</li> <li>Shall only be installed on gravity pipelines.</li> </ul>		✓	✓
Hynds PinnacleX	<ul style="list-style-type: none"> <li>DN525, DN600, DN675 and DN750 to meet Class 2 and Class 4</li> <li>When used for wastewater, pipes must be factory lined with PE or manufactured with approved additives and a sacrificial layer to achieve durability requirements.</li> <li>Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval.</li> <li>Shall only be installed on gravity pipelines.</li> </ul>		✓	✓
Elepipe RCRRJ Pipe	<ul style="list-style-type: none"> <li>DN225 – DN1600 only</li> <li>Rubber-ring jointed and Class 2 minimum.</li> <li>Shall not be installed in marine environments (as defined in AS/NZS 4058) without prior written approval.</li> <li>Shall only be installed on gravity pipelines.</li> </ul>			✓

## 2.7. Vitrified clay

Product	Notes	WS	WW	SW
Vitrified Clay AS 1741	Permitted only for invert tiles in manholes and chambers.		✓	

## 2.8. Profiled polyethylene and polypropylene pipes

Note: Profiled polyethylene and polypropylene pipes must be rubber-ring jointed and SN16 minimum.

Product	Notes	WS	WW	SW
CivilBoss Twin Wall Polypropylene Pipe	<ul style="list-style-type: none"> <li>• Rubber ring joints only.</li> <li>• Minimum SN16.</li> <li>• Pipes must not be used for pressure application.s</li> <li>• Nominal diameters in the range DN 225 – 450 only.</li> <li>• Must be installed by personnel trained to avoid shallow sockets resulting in joints “squeezing” out during installation.</li> <li>• Post installation connections must be installed using Fernco QwikSeals.</li> <li>• Pipelines must be designed and installed in accordance with AS/NZS 2566, the Regional Specification for Water Services, and the manufacturer’s instructions.</li> </ul>			✓
PKS Civil Pipe Spiral Wound PE100	<ul style="list-style-type: none"> <li>• Minimum SN16.</li> <li>• Pipes must not be used for pressure applications.</li> <li>• Nominal diameters in the range DN600 to DN1200 only.</li> <li>• Must be installed by personnel trained to avoid shallow sockets resulting in joints “squeezing” out during installation.</li> <li>• Post installation connections must be installed using Fernco QwikSeals.</li> <li>• Pipelines must be designed and installed in accordance with AS/NZS 2566, the Regional Specification for Water Services, and the manufacturer’s instructions.</li> </ul>			✓

### 3. Fittings, Couplings & Connectors

#### 3.1. Ductile iron fittings

Product	Notes
Ductile iron bends, tees, tapers, spools (AS/NZS 2280)	Fittings shall be protected from corrosion by a factory applied coating; eg Rilsan, Levasit etc.
Ductile iron bends, tees, tapers, spools (ISO 2531)	To be used with ISO 2531 DICL pipe only.



#### 3.2. Polyethylene electrofusion fittings

Product	Notes
Frialen (AS/NZS 4129)	
Plasson (AS/NZS 4129)	
Agru (AS/NZS 4129)	
Georg Fischer (AS/NZS 4129)	
Fusion Provida (AS/NZS 4129)	PE100 SDR11 fittings DN355 or smaller.



### 3.3. Polyethylene compression fittings – Repair Only

Compression fittings shall only be used for the repair of pipelines or to connect from a new pipeline to an old pipeline.

See also Mechanical Couplings for fittings for larger diameter PE.

Product	Notes
Talbot Pushfit (AS/NZS 4129)	<ul style="list-style-type: none"> <li>• For use on PE80b (MDPE) only</li> <li>• Up to 63mm OD only</li> <li>• To be used with inserts</li> </ul>
Philmac Metric (AS/NZS 4129)	<ul style="list-style-type: none"> <li>• For use on PE80b and PE100</li> <li>• Up to 63mm OD only</li> <li>• To be used with inserts</li> </ul>
Plassim (AS/NZS 4129)	<ul style="list-style-type: none"> <li>• For use on PE80b (MDPE) only</li> <li>• Up to 63mm OD only</li> <li>• To be used with inserts</li> </ul>
Plasson “Series One” (AS/NZS 4129)	<ul style="list-style-type: none"> <li>• For use on PE80b and PE100</li> <li>• Up to 63mm OD only</li> <li>• To be used with inserts</li> </ul>
Hansen “Easy Fit” (AS/NZS 4129)	<ul style="list-style-type: none"> <li>• For use on PE80b and PE100</li> <li>• Up to 63mm OD only</li> <li>• To be used with inserts</li> </ul>



### 3.4 Full faced reducing stub flanges (AS/NZS 4087)

Product	Notes
Simona PE100 HSCR injection moulded full faced flange with SS 316 backing ring	Not for use in water or wastewater pumpstations. Maximum size DN225. To be used with electrofusion or butt fusion welding.
Solo Plastics PE1226.250.200 Full Face Slim Flange	Not for use in water or wastewater pumpstations.



PN16 SDR11 With Nylon Backing Ring	Not for use in the bulk water network. Maximum size DN250. To be used with electrofusion or butt fusion welding.
Plasson PE100 HSCR Injection Moulded Full Face Flange with Stainless Steel 316 Backing Ring	Not for use in water or wastewater pumpstations. Not for use in the bulk water network. Maximum size DN375. To be used with electrofusion or butt fusion welding.

### 3.5 Mechanical couplings

All installed mechanical couplings shall be protected using the Denso paste and wrapping protection system.

Only to be used for transition joints from new to existing mains where non-mechanical joints are not practicable, and for repairs. Not to be used as a standard pipe jointing method on new pipelines.

Product	Notes
Viking Johnson range	Includes flange adapters and straight couplers. PN16 minimum.
AVK Supacoupler range	Includes flange adapters and straight couplers. PN16 minimum.
Tyco Vari-Gib	Includes flange adapters and straight couplers. PN16 minimum.
HIWA	Bolted unrestrained mechanical coupler (Product Code FC10-A only). DN80 to DN300. PN16. Ductile iron.  Flange adapter (Product Code FA10-A only). DN80 to DN300. PN16. Ductile iron.



### 3.6 Mechanical couplings for polyethylene pipes

All installed mechanical couplings shall be protected using the Denso paste and wrapping protection system.

Only to be used for transition joints from new to existing mains where non-mechanical joints are not practicable, and for repairs. Not to be used as a standard pipe jointing method on new pipelines.

PE restraint fittings to be used with pipe inserts.

Product	Notes
Georg Fischer Waga Multi/Joint 3000 Plus	PN16 minimum
AVK Supa Plus	PN16 minimum
Hawle System 2000	PN16 minimum
Hawle Synoflex	PN16 minimum
Viking Johnson UltraGrip	PN16 minimum
Promains Hermetica SS Permanent Repair Clamp	Approved for use on Wellington Water drinking water reticulation network.
Nova Siria Multigrip	PN16 minimum



### 3.7 Dismantling joints

Product	Notes
Viking Johnson	PN16 minimum
AVK Dismantling Joint	PN16 minimum
Hawle Vario	PN16 minimum. Not to be used for seismic flexibility.
HIWA Dismantling Joint	Product Codes FD10 and FD20. PN16 minimum. Ductile Iron. DN80 to DN300.



### 3.8 Flanged flexible joints

Product	Notes
Flex-tend	These fittings require special design with consideration towards unbalanced thrust and initiating forces.
Saint Gobain PAM Geoflex	



### 3.9 Tapping bands for water connections

Product	Notes
Plasson PN16 mechanical tapping saddle (PE80b)	For use 63OD pipe and smaller
RX Fittings (for PE pipe only)	For use 63OD pipe and smaller
Tapping bands for water mains	LG2 or Aluminium bronze, stainless steel, or fusion bonded epoxy coated DICI tapping band. Fully encircled, metal to metal seating and hydraulically activated lip seal.
Promains Hermetica SS Permanent Repair Clamp 380 mm clamp	For use on mechanically jointed bulk mains. Not for use on welded mains.



### 3.10 Repair clamps

Product	Notes
Promains Hermetica SS Permanent Repair Clamp 210 mm clamp	For use on pipes $\leq$ DN150 with cracks or holes $\leq$ 40 mm.
Promains Hermetica SS Permanent Repair Clamp 380 mm clamp	For use on pipes $\leq$ DN150 with cracks or holes $\leq$ 40 mm and on pipes $>$ DN150 with cracks or holes less than 40 mm.





### 3.11 Other

Product	Notes
Fernco QwikSeal	Only to be used in non-pressure applications for lateral connections to gravity pipes.



## 4. Valves

### 4.1 Gate valves – Resilient seated

#### 4.1.1. General use

Product	Notes
AVK series 57 (AS/NZS 2638.2)	>= 80 mm nominal diameter, anti-clockwise closing
Hawle E2 (AS/NZS 2638.2)	>= 80 mm nominal diameter, anti-clockwise closing
Hawle E3 Resilient Seated Gate Valves (AS/NZS 2638.2)	DN50 to DN300. For use in water supply network only. Clockwise closing DN50-DN80. Anti-clockwise closing DN80-DN300.
Sureflow Figure 500 (AS/NZS 2638.2)	>= 80 mm nominal diameter, anti-clockwise closing
Sufa / Maxiflo (AS/NZS 2638.2)	>= 80 mm nominal diameter, anti-clockwise closing
Derwent (P&I) (AS/NZS 2638.2)	>= 80 mm nominal diameter, anti-clockwise closing
HIWA Z1711EM & DGZ1711EM (AS/NZS 2638.2)	DN80 to DN300, anti-clockwise closing. FBE coated Ductile Iron. PN16. For use in water supply network only.
Hawle RS service valve	50 mm <b>Clockwise</b> closing with hand-wheel
AVK Series 57 service valve	50 mm <b>Clockwise</b> closing with hand-wheel



#### 4.1.2. Repair Only

Product	Notes
Daepoong S-Gate Valves	<ul style="list-style-type: none"> <li>• Anti-clockwise closing.</li> <li>• Nominal diameter sizes DN100, DN150, DN200, and DN250.</li> <li>• To be used on ductile iron, cast iron and asbestos cement (requires risk assessment) pipes only.</li> <li>• For water supply and pressure sewer applications only.</li> <li>• May only be used for repair work or temporary work, on an existing pipe in service, and where the cut-in of a traditional gate valve will result in an unacceptable service</li> </ul>



Product	Notes
	interruption as determined by Wellington Water’s Network Controller. <ul style="list-style-type: none"> <li>• Installation by fully trained personnel approved by CNS Engineering only.</li> <li>• Requires special consideration of socket pull-out of the pipe and valve due to differential thrust from the valve.</li> </ul>

#### 4.2. Check valves

Product	Notes
Check Valve – AVK Swing Check	For mains 80 mm and above (water supply only).
Check Valve – Valmatic Surgebuster	For pressure applications on wastewater, stormwater or water supply.



#### 4.3. Globe control valves – Pressure reducing, sustaining and relief valves

Product	Notes
Bermad	
Cla-Val	



#### 4.4. Service valves (Tobies)

Also see Section 6.4 Surface Boxes.

Product	Notes
Acuflo DR Brass Manifold (20 mm NB)	GM900 with dual-check valve.
Acuflo Composite Manifold (20 mm NB)	May be used ONLY when metallic manifolds are not available.
Acuflo DR brass diaphragm valve (20 mm NB)	Must be installed with downstream approved dual-check valve.



Gate valves (see <b>Section 4.1</b> )	Can also be used as service valves with larger services > 20 mm.
---------------------------------------	--

#### 4.5. Backflow prevention Devices

Product	Notes
Wilkins-Zurn	<ul style="list-style-type: none"> <li>BFP type to be determined by Council in conjunction with activity hazard class.</li> <li>To comply with AS/NZS 2845.1.</li> </ul>
Watts	
Febco	
Pentair-ValCheQ	



#### 4.6. Hydrants

All hydrants shall be clockwise closing and without frost plugs.

Product	Notes
Gillies Metaltech Hydrant (NZS 4522)	
AVK (NZS 4522)	



#### 4.7. Other valves

Product	Notes
Mainscock – Tita gunmetal in-line ball valve	Used mostly when tapping under pressure.



## 5. Water Meters

All meters should comply with the requirements of OIML R49. Also see Section 6.4 Surface Boxes.

Product	Notes
Sensus 640 (based on Deeco 620 with automated meter reading)	<ul style="list-style-type: none"> <li>• Service connections DN 20 or less only.</li> <li>• Requires removal for calibration every 10 years.</li> <li>• Requires supporting systems for automated meter reading.</li> </ul>
Sensus iPerL inline meter (based on Deeco 620 with smart meter reading)	<ul style="list-style-type: none"> <li>• Service connections DN 40 or less only.</li> <li>• Requires supporting systems for smart meter reading.</li> </ul>
Sensus (formerly Socam and Meinecke)	<ul style="list-style-type: none"> <li>• 620B/C/MB/MC (min. R160).</li> <li>• Meitwin combination meters.</li> <li>• Sensus Meistream Plus “Class C” min. R315 (DN50 to DN80 only).</li> </ul>
Elster-Kent	<ul style="list-style-type: none"> <li>• In-line and manifold type meters.</li> <li>• Combination meters.</li> <li>• H5000 Woltmann (extended version – R1250).</li> </ul>
ABB Watermaster	<ul style="list-style-type: none"> <li>• Magnetic flow meter.</li> <li>• Can be used for wastewater also if full bore flow is continuously maintained such as within pumping stations.</li> </ul>
Itron (formerly Actaris and Neptune)	<ul style="list-style-type: none"> <li>• In-line meters only.</li> </ul>
Sappel (Diehl)	<ul style="list-style-type: none"> <li>• In-line and manifold meters.</li> </ul>



## 6. Manholes and Streetware

### 6.1. Manhole covers

These covers are to be used on standard manhole installation for sewage and stormwater applications.

Product	Notes
WCC Patterned "Maestro" Class E ductile iron AS 3996	Hinged. To be used in WELLINGTON CITY ONLY.
HCP ductile iron hinged frame and centre WCC Pattern (EN124)	Hinged. To be used in WELLINGTON CITY ONLY.
"Maestro" Class E ductile iron (standard pattern) AS 3996	Hinged. To be used only outside of Wellington city.
HCP ductile iron hinged frame and centre Standard Pattern (EN124 D400)	Hinged. To be used only outside of Wellington city.
Humes Ductile Iron Hinged Manhole Cover Set - 80082098	Hinged. To be used only outside of Wellington city.
Pamrex 600 D400 Manhole Frame and Cover	Hinged. Not for use in airports and loading yards.  WCC Only: Must be stamped with the WCC Pattern. Other Councils: Use standard pattern.



## 6.2. Manhole safety grilles

Product	Notes
Impact Engineering – Maestro	Fits Maestro
Impact Engineering - Hygrade HD	Fits Hygrade HD 485mm (not for new lids, retrofit only)
Impact Engineering - Hygrade LD	Fits Hygrade LD 510mm (not for new lids, retrofit only)
T & T Bennett - MSG610S/S	Fits Maestro
T & T Bennet - 48503	Fit Humes lids 460mm opening (not for new lids, retrofit only)
Calibre - CSG600SSM	Fits Maestro lids



## 6.3. Prefabricated manholes systems

Product	Notes
Hutt Concrete Products Twin Lake <sup>®</sup> Concrete Manhole System	<b>Approved for Trial use only. Approval may be revoked at any time.</b>
Hynds - Pinnacle Manhole	Approval includes PE encapsulated galvanised iron step system.
Hynds - PERFECT Manhole System	Can only be used on storm water network. Manholes shall not be installed on PE pipelines.
Hynds - Hyspec Manhole System	
Elepipe Manhole System	DN1050 – DN1800 only.
Humes - Concrete Manhole Systems	



#### 6.4. Surface boxes

Product	Notes
Channell HDPE bulk pits	<ul style="list-style-type: none"><li>• Can only be used on drinking water distribution network.</li><li>• Must not be installed in road carriageway.s</li><li>• Box and lid must be rated to a minimum of AS 3996 Class C.</li><li>• Lid must meet the slip resistance requirements of the NZ Building Code Section D2.1.2 Slip Resistance.</li><li>• Lid must have blue “Water” coded insert.</li></ul>

